2012 LEBANON TN SSOER

*Map Ref. #	Address/ Location	Date	Duration of Overflow (hrs)	Estimated Volume (gallons)	Basin	Cause of the Overflow	Measure taken to stop the Overflow	Short Term Control List	Long Term Planning and Remediation	Manhole #
	Rainfall Related									
1	604 Fairgrounds Ct.	8/4/12	3 hrs. 45 min.	25 gpm	Coles Ferry	I & I from heavy rainfall	no action taken		X	1753
	Non- Rainfall Related									
2	500 Peyton Rd. - Peyton Rd. Apart.	1/10/12	1 hr. 12 min.	estimated 1gpm	Sinking Creek	main line stopped up	unstopped main line	X		20982
3	Field behind TRW	2/15/12	1 hr. 35 mim.	estimated 50gpm	Bartons Creek	main line stopped up	unstopped main line	X		432
4	125 Bethlehem Rd. Pump Station #25	3/17/12	1 hr. 32 min.	unknown	Summercrest	pump stopped up	pulled and cleaned pump	X		PS #25
5	643 Five Oaks Blvd.	5/12/12	5 min.	estimated 100 gal. total	Babb	main line stopped up	pulled out string & debris	X		966
6	Soccerfield PS #27 off Castle Heights	6/27/12	30 min.	estimated 15 gal.	Tarver Branch	pump station was cut off	turned pump station back on	X		PS #27
7	1639 Murfreesboro Rd.	7/20/12	28 min.	estimated at 20gpm	Sinking Creek	capaciter out on pump station	pumped & hauled/replaced capaciter	X		PS #28
8	226 Beard Ave.	7/13/12	2 hr. 5 min.	15 gpm	Sinking Creek	grease blockage concurrent with high flow	Cleaned main line. Removed grease blockage	X		2239
9	off I-840 Amazon Site	7/26/12	30 min.	estimated at couple thousand gallons	Bartons Creek	12" force main broken	replaced 20' of 12" pipe	X		Force Main
10	413 S. Maple St.	8/4/12	1 hr. 26 min.	estimated 100gpm	Sinking Creek	pipe restricted by grease	cleaned main line	X		1371
11	524 Trousdale Ferry (Spring Hill Apts.)	8/12/12	1 hr. 45 min.	15gpm	Sinking Creek	main line stopped up w/grease	cleaned main line	X		462
12	Powell Lake PS #54	8/23/12	41 min.	15gpm	Babb	power outage	MTEMC was notified	X		PS #54
13	intersection of Vanhook & Castle Heights	8/28/12	23 hrs. 57 min.	< 1gpm	Tarver Branch	small crack in 4" force main off Thorne Ct PS #2	excavated and repaired 4" force main	X		PS #2
14	Five Oaks PS #42	9/14/12	20 min.	1000 gal. pooled on ground	Babb	broken 6" force main	repaired with 5' of 6" SDR 35 & 2 -6" wrap sleeves	X		PS #42
15	802 Tennessee Blvd.	11/18/12	42 min.	100 gal. on parking lot	Sinking Creek	main line stopped up	unstopped main line	X		29782 & 2203
16	604 E. Main St. (Allen's Market PS #9)	11/19/12	15 min.	estimated at 10 gal. total	Sinking Creek	Bush Const. hit PS 6" force main	repaired with repair sleeve	X		PS #9
17	Five Oaks PS #33	11/19/12	1 min.	25 gpm	Babb	pump station was cut off	turned pump station back on	X		PS #33