

Wastewater Plant

Parking

Less than 25 parking spaces with none designated accessible.

ADAAG: Parking lots with 1 to 25 total parking spaces require a minimum of one van accessible space (208).

Entrance

There is a $\frac{3}{4}$ " separation between the door landing and the door. The exterior door has a $\frac{3}{4}$ " high threshold that is not beveled on the inside.

ADAAG: Openings in floor or ground surfaces shall allow passage of a sphere not more than $\frac{1}{2}$ " diameter (302.3). Existing or altered thresholds $\frac{3}{4}$ " high maximum that have a beveled edge on each side are allowable (Exception to 404.2.5).

The entrance has two doors in series with less than 48" between the doors when the interior door is open.

ADAAG: The distance between two hinged or pivoted doors in series should be 48" minimum plus the width of any door swinging into the space (404.2.6).

Interior Path of Travel

The interior doors have doorknobs for operating devices.

ADAAG: Operable parts shall be operable with one hand and shall not require tight grasping, pinching, or twisting of the wrist (309.4).

Restroom

The uni-sex restroom's water closet has parallel grab bars.

ADAAG: Grab-bars shall be provided on the rear wall and on the sidewall closest to the water closet (604.5).

The lavatory in the uni-sex restroom is 36" high, its pipes are not insulated, and the mirror is 50" above the floor.

ADAAG: Lavatories shall be installed with the front of the higher of the rim or counter surface 34" maximum above the floor (606.3). Water supply and drainpipes under lavatories shall be insulated or otherwise configured to protect against contact (606.5). Mirrors shall be installed with the bottom edge of the reflecting surface 40" maximum above the floor (603.3).