

Water Plant

Parking

There are no marked parking spaces. There is an upright symbol of accessibility sign along the curb by the entrance. There are no markings for a vehicle space or access aisle.

ADAAG: Access aisles shall be marked so as to discourage parking in them (502.3.3).

Path of Travel

The designated entrance is accessible and has a doorbell with the directions to ring the bell if you need assistance. The entry foyer has long stairs to the main level and the plant is on many levels and all accessed by steps and stairs.

This facility is secured with a fence, closed gate, and security guard. The public does not normally come to this building. The manager said they have had occasional tours in the past but it has been two years since the last tour.